




- +B BOILER POWER BOARD  
-F1xx HEATER FUSE "B" 32A  
-K100 SAFETY THERMOSTAT RELAY  
-Kx HEATER CONTACTOR  
+B0 HEATER BOX  
-Ex HEATER 15kW
- TIGHTENING:  
30Nm BUSBAR  
30Nm MAIN CONNECTOR


\* SEE TABLE FOR TECHNICAL CHARACTERISTIC FOR FUSES, WIRE DIMENSIONS AND HEATER USE








### REGULATION BOARD




### POWER UP STEPS TABLE

STEP	HEATER GROUP			POWER [kW]
	S1	S2	S3	
1.	☒	☐	☐	30
2.	☐	☒	☐	60
3.	☒	☒	☐	90
4.	☐	☐	☒	165
5.	☒	☐	☒	195
6.	☐	☒	☒	225
7.	☒	☒	☒	255

### MECHANICAL PLAN



### HEATER CONNECTION



☐ OFF  
☒ ON

### HEATERS POSITIONS

